



SUTTER COUNTY ENVIRONMENTAL HEALTH DIVISION
 DEVELOPMENT SERVICES DEPARTMENT
 1130 Civic Center Boulevard, Suite A
 Yuba City, CA 95993
 Ph# (530) 822-7400 Fax# (530) 822-7220

Date 9-22-17
 Page 1 of 2

RETAIL FOOD FACILITY INSPECTION REPORT

DBA: Bonanza Convention Center

Address: _____ City: _____ Zip: _____ Phone: _____

Change of Ownership

ITEM/LOCATION	TEMP.	ITEM/LOCATION	TEMP.

OBSERVATIONS AND CORRECTIVE ACTIONS

- Provide hand sink at bar with hand soap and paper towels in sanitary dispensers.
- Provide dedicated hand sinks in utensil cleaning and prep areas with hand soap and paper towels in sanitary dispensers.
- Unable to verify hot ~~water~~ water due to burst pipe. Minimum 120°F hot water required at utensil, prep and mop sinks. Minimum 100°F hot water required at all hand sinks.
- Replace existing ice bin with cold plates with approved ice bin with integral cold plates. (OK to muddle procedure until 3/27/18 - then provide approved ice bin)
- Provide weather strip between glass entry doors to prevent the entrance of vermin.
- Replace missing/burned out lights over

Owner/Operator: [Signature] Title: _____

REHS: Kimberly Hart



SUTTER COUNTY ENVIRONMENTAL HEALTH DIVISION
 DEVELOPMENT SERVICES DEPARTMENT
 1130 Civic Center Boulevard, Suite A
 Yuba City, CA 95993
 Ph# (530) 822-7400 Fax# (530) 822-7220

Date 9-22-17
 Page 2 of 2

RETAIL FOOD FACILITY INSPECTION REPORT

DBA: Bonanza Event Center
 Address: _____ City: _____

OBSERVATIONS AND CORRECTIVE ACTIONS

- dishwasher
- Utensil sink and dish washer directly plumbed. Provide indirect drainage to floor sink. (OK on performance basis)
- Some broken, missing cove base tile and/or grout by back door, prep area. Repair/replace where needed to be smooth and easily cleanable.
- No covering at area under bar. Provide with minimum 3/8" radius that extends up bar at least 4 inches. Note: Top set covering is not allowed. Contact Kimberly for specific requirements.
- No cove in restrooms; 90° angle at floor-wall junction. Provide minimum 3/8" radius cove in restrooms. (OK on performance basis)
- Replace missing floor tile in restrooms - and ensure floor drains are functioning properly.

Owner/Operator Init: [Signature]

REHS Init: [Signature]