



RETAIL FOOD FACILITY INSPECTION REPORT

DBA: Deli @ El Joro Market

Address: 240 Garden Hwy City: YC

Pre-final (2)

OBSERVATIONS AND CORRECTIVE ACTIONS

- Provide minimum 120°F hot water at utensil and prep sinks.
 - Seal gaps between FRP panels (use strips) to prevent damage to wall from water.
 - Repair utensil sink drain pipe where leaking.
 - Remove paint board from prep sink. Okay to provide stainless flashing.
 - Provide Manager's Food Safety certificate for at least 1 food handler.
 - Submit application and fee for a permit to operate to this Division after final and before opening.
- Re-inspection fees apply to subsequent inspections.

Owner/Operator Init: NA

REHS Init: KMH