



RETAIL FOOD FACILITY INSPECTION REPORT

DBA: Wilbur Market

Address: 201 Wilbur City: YC

Change of Ownership

OBSERVATIONS AND CORRECTIVE ACTIONS

- Clean wood shelves to remove beverage residues and re-seal to be nonabsorbent. Note: Metal shelves required on replacement.
- Repair flooring in back storeroom to be smooth and easily cleanable. Provide covering in both back soda storage areas. Top set rubber covering okay in this area ONLY.
- Provide mop sink with hot and cold running water.
- Replace unapproved 2-compartment sink with 3-compartment sink with dual drainboards. Note: Basins only need to be large enough to submerge ice scoop.
- Replace broken faucet handle (hot water) if used on new sink.
- Seal gap in ceiling in utensil sink room to prevent the harboring

Owner/Operator Init: [Signature]

REHS Init: [Signature]



RETAIL FOOD FACILITY INSPECTION REPORT

DBA: Willbur Market
 Address: 201 Willbur City: YC

OBSERVATIONS AND CORRECTIVE ACTIONS

- of Vermont
 Clean/^{remove} miscellaneous items from floor in utensil sink area/under utensil sink.
- Board approved flooring (vinyl, floor tile, etc.) and covering in /around utensil sink, ice machine and beverage syrup racks. Covering must have a minimum 3/8 inch radius and extend up floor at least 4 inches.
- Wood frame at restroom hand sink not approved. Must be replaced with approved method of securing sink at first sign of water damaged wood at floor / failure to hold safely, etc.

Call for re-inspection when work complete. Guidelines for flooring available on Sutter County website (Sutter County Dept)

Owner/Operator Init: [Signature]

REHS Init: [Signature]