



SUTTER COUNTY ENVIRONMENTAL HEALTH DIVISION
 DEVELOPMENT SERVICES DEPARTMENT
 1130 Civic Center Boulevard, Suite A
 Yuba City, CA 95993
 Ph# (530) 822-7400 Fax# (530) 822-7220

Date 8.12.20
 Page 1 of 1

RETAIL FOOD FACILITY INSPECTION REPORT

DBA: Los Portales
 Address: 441. Bridge City: YC
Re-inspection (1)

OBSERVATIONS AND CORRECTIVE ACTIONS

Burners and large pots situated under the hood in a manner that provides the required hood overhang (6 inches). Violation corrected.

Continue to ensure proper overhang (6 inches from cooking surface) for all cooking in the future.

Owner/Operator Init: J.Lc

REHS Init: [Signature]