



**RETAIL FOOD FACILITY INSPECTION REPORT**

DBA: Wellness Market  
 Address: 201 Wellborn City: YC

Change of Ownership Re-inspection (1)

**OBSERVATIONS AND CORRECTIVE ACTIONS**

- Provide approved flooring and coving in utensil cleaning area / prep sink area within 6 months. Coving MUST extend up wall at least 4 inches with a minimum 3/8 inch radius.
- Unapproved / top set coving okay in beverage & storage rooms but refrigerators and freezers, etc. may not be placed in this area.
- Remove wood "frame" holding up restroom hand sink and provide stainless legs if needed.  
 now  
 Okay for facility owner to take over / operate.

Note: Floor drain must be provided at utensil sink if any food prep started in future.  
 Owner/Operator Init: S. Alshamir REHS Init: [Signature]