



SUTTER COUNTY ENVIRONMENTAL HEALTH DIVISION
 DEVELOPMENT SERVICES DEPARTMENT
 1130 Civic Center Boulevard, Suite A
 Yuba City, CA 95993
 Ph# (530) 822-7400 Fax# (530) 822-7220

Date 10-2-2020
 Page 1 of 1

RETAIL FOOD FACILITY INSPECTION REPORT

DBA: Los Charros Taqueria
 Address: 425 Colusa Avenue City: Yuba City

Re-inspection

OBSERVATIONS AND CORRECTIVE ACTIONS

② - Food cooking equipment still directly beneath/beyond edge of hood overhang at cookline and back prep area. Provide at least 6" ~~inches~~ inches overhang of hood over cooking equipment (e.g., pots, stoves, burners, etc.).

- Soda beverage dispenser has no signage regarding "No customer self-service, ask staff for help". Staff reports staff ~~dispenses~~ ^{dispenses} beverages but customers occasionally self-service. Per Brcounty Health Officer and State orders, no customer self-service is allowed at this time. Staff only is allowed to dispense beverages. Provide signage regarding no customer self-service on soda machine.

Re-inspection to follow in 7+ days.
 Re-inspection fees apply to subsequent inspections where the above violations are observed.

Owner/Operator Init: A.V

REHS Init: JR