



SUTTER COUNTY ENVIRONMENTAL HEALTH DIVISION
 DEVELOPMENT SERVICES DEPARTMENT
 1130 Civic Center Boulevard, Suite A
 Yuba City, CA 95993
 Ph# (530) 822-7400 Fax# (530) 822-7220

Date 10.6.20
 Page 1 of 1

RETAIL FOOD FACILITY INSPECTION REPORT

DBA: Jack in The Box
 Address: Sharp City: YC
Complaint

OBSERVATIONS AND CORRECTIVE ACTIONS
Received complaint that facility's air conditioning unit was non-operational (again).
On arrival, District Manager on site. Reported unit had broken down yesterday but it had already been repaired.
Air temperature at cook line 86°F - 89°F during inspection (61°F - 70°F at return air vents).
Keep portable air conditioning units on site until sure main unit won't break down again.

Owner/Operator Init: [Signature]

REHS Init: [Signature]